

9. Section F-301.2 (page 29, line 3); ~~ADD~~ the following:

"Burning shall be prohibited in all commercial occupancies and multifamily residential structures. Burning of normal household rubbish from one and two family dwelling shall be prohibited except in approved incinerators. Leaves, trimmings or prunings may be burned in a pile. No burning is permitted within 50 feet of any combustible structure or within any highway drainage ditch or on any highway."

10. Section F-301.4.1 (page 29, line 3) ~~DELETE~~: "burning not longer than 3 hours."
INSERT:

"not be allowed before sunrise or 2 hours before sunset as defined by the National Weather Service."

11. Section F-301.7 (page 30, line 3); ~~DELETE~~: "Fires in approved containers shall be permitted provided that such fires are not less than 15 feet (4572 mm.) from any structure."

12. Section F-313.2 (page 35, line 2); ADD:

"All fire lanes located on stoned or other natural surface shall be marked with vertical signs stating 'NO PARKING FIRE LANE' or 'NO PARKING BY ORDER OF FIRE MARSHAL,' and on all other designated fire lanes located on hard top (concrete or asphalt or the like) shall have additional markings on the horizontal surface stating 'NO PARKING FIRE LANE.'"

13. Section F-313.4 (page 35); ADD:

F-313.4 Enforcement: The Fire Marshal shall have the authority to enforce parking regulations in approved fire lanes and shall be authorized to issue citations for violations. Fines for each violation shall not exceed Twenty-Five Dollars (\$25.00) plus appropriate court costs.

14. Section F-317.2 (page 37, line 2); ~~DELETE~~: "more than 25 pounds (11.35 kg.)"

15. Page 38, INSERT:

"Section F-319.0 Dumpsters

F-319.1 General: This section shall control the location or placement of dumpsters, inside or outside of buildings or structures.

F-319.2 Inside Placement: The placement of dumpsters inside buildings or structures shall be permitted provided the dumpster has a properly fitted noncombustible lid and the lid is kept closed at all times when not being filled and that the room or area has an approved fire early warning device suitable for the location. The room or area must be of fire resistant construction of at least one (1) hour.

F-319.3 Outside Placement: The placement of dumpster outside of a building or structure shall be no less than five (5) feet (1524 mm.) from any

Burning